

# CERTIFICATE

## Permission to Use the Test Mark

### *VOLUNTARY TEST OF SEPARATION EFFICIENCY*

*– Effective protection against fine dust and toner dust –*

TÜV NORD Systems GmbH & Co. KG, Hamburg,  
confirms that the


## **"micronAir<sup>®</sup> office" filters for laser printers**

fulfil the requirements set by TÜV NORD Systems GmbH & Co. KG  
if a filter flow velocity of  $\leq 2$  m/min is maintained.

**Freudenberg Vliesstoffe KG, Weinheim,**

is therefore granted the right to use the test mark shown below, together with  
the explanatory note, in connection with the aforementioned products.

TÜV NORD Systems GmbH & Co. KG  
Testing Laboratory for Indoor Air Hygiene



Dipl.-Ing. R. Schüler

Essen, 30 October 2007

**Criterion for this test mark:**

Average separation rate of  
particles of 0.1 to 2.0  $\mu\text{m}$   
 $\geq 85\%$  at a filter flow velocity  
of  $\leq 2$  m/min

